

Criteria for Designating a BASE Building Space as a Study Area(s)		
Characteristic	Criteria	
	Necessary	Preferred
Number of Occupants	25 occupants who work for 20 or more hours/week and are accessible to questionnaire	50 to 60 occupants who work for 20 or more hours/week and are accessible to questionnaire
Air Supply	Provided by no more than two air handling units	Provided by one air handling unit
Test Space	Totally contained in a maximum of three floors	Totally contained on one floor
Test Area	---	Not to exceed 20,000 square feet ^a
^a Can be larger; however, deviation should be documented.		