

**BASE Buildings HVAC Characteristics:** Control System - Frequency of Inspection and Sensor Calibration

Frequency of Actions	Number of Buildings Reporting	
	Frequency of Control System Inspection <sup>1</sup>	Frequency of Sensor Calibration <sup>2</sup>
None	12	15
As Needed	28	58
Daily	14	0
Weekly	2	0
Bi-Weekly	1	0
Monthly	4	4
Semi-Quarterly	0	0
Quarterly	12	3
Semi-Annually	11	7
Annually	14	10
Total Number of Buildings Reporting	98	97
<b>Notes:</b>		
<sup>1</sup> Data represent 98 BASE buildings, which indicated an inspection frequency.		
<sup>2</sup> Data represent 97 BASE buildings, which indicated a calibration frequency.		

Variable Descriptions:

**Frequency of Control System Inspection** refers to the frequency of inspection for the heating, ventilating, and air conditioning system control system.

**Frequency of Sensor Calibration** refers to the frequency of sensor calibration for the heating, ventilating, and air conditioning system control system.

The frequency categories are as follows:

**None** means that no inspections or calibrations take place.

**As Needed** refers to an inspection or calibration schedule that occurs only when deemed necessary.

**Daily** refers to an inspection or calibration schedule where inspection occurs each day.

**Weekly** refers to an inspection or calibration schedule where inspection occurs on a weekly cycle.

**Bi-weekly** refers to an inspection or calibration schedule where inspection occurs twice a month.

**Monthly** refers to an inspection or calibration schedule where inspection occurs on a monthly schedule.

**Semi-Quarterly** refers to an inspection or calibration schedule where inspection occurs twice every three months.

**Quarterly** refers to an inspection or calibration schedule where inspection occurs every three months.

**Semi-annually** refers to an inspection or calibration schedule where inspection occurs every six months.

**Annually** refers to an inspection or calibration schedule where inspection occurs once a year.