

BASE Buildings HVAC Characteristics: Heating and Cooling Profiles - Number of Space Conditioning and Ventilation Hours Per Day

	Number of Space Conditioning Hours Per Weekday	Number of Space Conditioning Hours Per Weekend Day ¹	Number of Ventilation Hours Per Weekday ²	Number of Ventilation Hours Per Weekend Day ³
Number of Buildings Reporting	100	98	99	97
Mean (Arithmetic)	17	13	17	12
Standard Deviation	5	9	6	9
Minimum	7	0	0	0
10th Percentile	11	0	11	0
25th Percentile	12	5	12	5
50th Percentile	16	12	16	9
75th Percentile	24	24	24	24
90th Percentile	24	24	24	24
Maximum	24	24	24	24

Notes:

¹Two buildings did not report the number of space conditioning hours per weekend day.

²One building did not report the number of ventilation hours per weekday.

³Two buildings did not report the number of ventilation hours per weekend day.

Variable Descriptions:

Number of Space Conditioning Hours Per Weekday refers to the number of hours per weekday that the building's space conditioning systems are reported to be operating.

Number of Space Conditioning Hours Per Weekend Day refers to the number of hours per weekend day that the building's space conditioning systems are reported to be operating.

Number of Ventilation Hours Per Weekday refers to the number of hours per weekday that the building's ventilation systems are reported to be operating.

Number of Ventilation Hours Per Weekend Day refers to the number of hours per weekend day that the building's ventilation systems are reported to be operating.