

**BASE Buildings Test Space HVAC Characteristics:** Central Air Handling and Distribution Systems - Return Air Fan

	Number of Test Space Air Handlers <sup>1</sup>
Central Air Handling and Distribution System Incorporates a Return Air Fan	45
<u>Notes:</u> <sup>1</sup> As reported for a total of 141 study space air handling units.	

Variable Description:

***System Incorporates a Return Air Fan*** describes the number of BASE test space air handling units that were equipped with a return air fan.