

BASE Buildings Test Space HVAC Characteristics: Central Air Handling and Distribution Systems - Variable Supply Air Temperature Setpoint

	Number of Test Space Air Handlers ¹
Central Air Handling and Distribution System Incorporates Variable Supply Air Temperature Setpoint	49
<u>Notes:</u> ¹ As reported for 91 AHUs indicating VAV as system type.	

Variable Description:

Central Air Handling and Distribution System Incorporates Variable Supply Air Temperature Setpoint describes the number of test space air handling that are eligible to incorporate variable supply air temperature setpoint control, and the number of eligible air handling units that use this control. This control strategy applies to variable air volume (VAV) air handling units.