

BASE Buildings Test Space HVAC Characteristics: Central Air Handling and Distribution Systems - Percentage of Air Handling Unit (AHU) Capacity Serving Test Space

	Central Air Handling and Distribution Systems - Percentage of AHU Capacity Serving Test Space
Number of Test Space Air Handlers	141
Mean (Arithmetic)	70
Standard Deviation	35
Minimum	4
10th Percentile	16
25th Percentile	34
50th Percentile	100
75th Percentile	100
90th Percentile	100
Maximum	100

Variable Descriptions:

Percentage of AHU Capacity Serving Test Space describes the percentage of the AHU capacity serving the test space, for each AHU. This value was usually determined based on the air handling unit's design air volume delivery rate compared to the air volume delivery rate that the air handling unit delivered to the test space.